

**Structural Calculations for
EOU Inlow Hall Generator**

Job Number: 230928

Codes: 2022 OSSC / 2021 IBC

Date: 2/6/24

Location: One University Blvd.
La Grande, OR 97850

Client: Fluent Engineering
2110 State St.
Salem, OR 97301
Phone: 503-447-5030

Engineer: John Carstensen, P.E., S.E.
MSC Engineers, Inc.
3470 Pipebend Place NE, Suite 120
Salem, OR 97301
Phone: 503-399-1399



Scope of Services: Calculation of anchorage forces and foundation design for Kohler 500REZXD with steel weather enclosure.

<u>Contents:</u>	Calculations	1.1 – 1.9
	Addendum: Generator Drawings	A.1 – A.3

LIMITATIONS: Engineer was retained in a limited capacity for this project. Design is based upon the information provided by the client, who is solely responsible for accuracy of same. No responsibility and/or liability is assumed by, or is to be assigned to the Engineer for items beyond those shown on these sheets.

GENERATOR ANCHORAGE

Reference: 2022 OSSC, ASCE 7-16

Generator Design Info:

Weight = 19122 lbs.

(Generator + Enclosure)

Length = 248.1 in or 20.68 ft
Width = 86.3 in or 7.19 ft
Height = 106.2 in or 8.85 ft
Center of Gravity (H_{CG}) = 53.5 in or 4.46 ft

Loads - WIND

V = 102 mph	Wind Speed, 3 Sec. Gust	(2019 OSSC: Table 1609.3)
Exposure = C	Wind Exposure Category	(ASCE 7-16: Section 26.7.3)
$K_d = 0.85$	Wind Directionality Factor	(ASCE 7-16: Section 26.6)
$K_{zt} = 1.0$	Topographic Factor	(ASCE 7-16: Section 26.8.2)
$K_e = 1.0$	Ground Elevation Factor	(ASCE 7-16: Section 26.9)
G = 0.85	Gust Factor	(ASCE 7-16: Section 26.11)
Cf = 1.30	Force Coefficient	(ASCE 7-16: Figure 29.4-1)
$k_h = 0.85$	Velocity Pressure Coeff.	(ASCE 7-16: Table 26.10-1)
$q_h = 19.24$ psf	Velocity pressure at avg. roof height	(ASCE 7-16: Equation 26.10-1)
F = 21.26 psf	Design Wind Pressure	(ASCE 7-16: Equation 29.4-1)
A = 110.10 sf	Largest Cross Sectional Area	

Ftotal = 2,341 lbs

Design Wind Force

Loads - SEISMIC

Site Class = D	Soil Site Class	(2019 OSSC: Table 1609.3)
Risk Category = II	Occupancy Risk Category	(2019 OSSC: Table 1604.5)
$S_{DS} = 0.339$	Design spectral accel. ($T = 0.2s$)	
$I_p = 1.5$	Component Importance Factor	(ASCE 7-16: Section 13.1.3)
$a_p = 1.0$	Component Amplification Factor	(ASCE 7-16: Table 13.6-1)
$R_p = 2.50$	Component Response Modification Factor	(ASCE 7-16: Table 13.6-1)
$\Omega_o = 2.00$	Overstrength Factor	(ASCE 7-16: Table 13.6-1)
$z/h = 0.0$	Height ratio for attachment	

$F_{p,max} = 0.81 * W_p = 1.6 S_{ds} I_p W_p$ (ASCE 7-16: Equation 13.3-2)

$F_{p,min} = 0.15 * W_p = 0.3 S_{ds} I_p W_p$ (ASCE 7-16: Equation 13.3-4)

$F_p = 0.08 * W_p = (0.4 S_{ds} I_p a_p / R_p)(1 + 2 z/h)$ (ASCE 7-16: Equation 13.3-1)

Ftotal = 2,917 lbs

Design Seismic Force

<- CONTROLS DESIGN

Address:
No Address at This Location

Standard: ASCE/SEI 7-16



Latitude: 45.320253

Risk Category: II

Longitude: -118.090177

Soil Class: D - Default (see Section 11.4.3)

Elevation: 2805.2521649649166 ft (NAVD 88)



Wind

Results:

Wind Speed	101 Vmph	USE 102 MPH
10-year MRI	70 Vmph	PER OSSC TABLE 1609.3
25-year MRI	77 Vmph	
50-year MRI	81 Vmph	
100-year MRI	86 Vmph	

Data Source: ASCE/SEI 7-16, Fig. 26.5-1B and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Mon Jan 29 2024

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).


Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.

Site Soil Class: D - Default (see Section 11.4.3)


Results:

S_S :	0.331	S_{D1} :	0.191
S_1 :	0.121	T_L :	16
F_a :	1.535	PGA :	0.148
F_v :	2.357	PGA _M :	0.223
S_{MS} :	0.509	F_{PGA} :	1.504
S_{M1} :	0.286	I_e :	1
S_{DS} :	0.339	C_v :	0.921


Seismic Design Category: C
MCE_R Response Spectrum




Design Response Spectrum



MCE_R Vertical Response Spectrum



Design Vertical Response Spectrum



Data Accessed: Mon Jan 29 2024

Date Source:

USGS Seismic Design Maps based on ASCE/SEI 7-16 and ASCE/SEI 7-16 Table 1.5-2. Additional data for site-specific ground motion procedures in accordance with ASCE/SEI 7-16 Ch. 21 are available from USGS.

Overturning Moment

M_{wind}	=	11,395	ft-lbs	Overturning Moment ($1.0W * 0.55H$)
$M_{seismic}$	=	13,010	ft-lbs	Overturning Moment ($1.0E * Hcg$)

Resisting Moment

DL Factor	=	0.932		= $1.0 - 0.2Sds$
$M_{resisting}$	=	64,083	ft-lbs	= $(P_{DL} * width / 2) * DL_{factor}$

Design Footing

		no		Use resisting moment for overturning?
M_a	=	9107	ft-lbs	Max Service Overturning Moment = $(0.6W \text{ or } 0.7E) - 0.6D$
P_{allow}	=	1500	psf	Allowable bearing pressure
$P_{passive}$	=	150	psf/ft	Lateral bearing pressure
$\sigma_{friction}$	=	0.25		Coeff. of friction
Width	=	8.19	ft	Minimum footing width (assume 6" edge distance)
Length	=	21.68	ft	Minimum footing length (assume 6" edge distance)
Thickness	=	8	in	Slab Thickness
A	=	177.56	ft ²	Area (width x length)
S	=	242.37	ft ³	Section Modulus ($bh^2 / 6$)
q_{max}	=	145	psf	Max bearing pressure w/ rigid slab ($P/A + M/S$)

USE 8'-2" WIDE x 21'-8" LONG x 8" THICK SLAB
W/ #5 BARS @ 16" OC (MAX) EA. WAY

Design Anchorage

		yes		Use resisting moment for overturning?
Ω_o	=	2.00		Overstrength Factor
		yes		Seismic controlled? ($Is \Omega E > W$)
M_u	=	(38,063)	ft-lbs	Ultimate Overturning Moment (LRFD - ΩE or $1.0W$)
V_u	=	5,834	ft-lbs	Ultimate Base Shear (LRFD - ΩE or $1.0W$)
n	=	5		Number of anchors each side.
x	=	6.83	ft	Distance between anchors
$U_{u,i}$	=	-1115.4	lbs	Ultimate Tension on Single Anchor (negative means no uplift)
$V_{u,i}$	=	583.4	lbs	Ultimate Shear on Single Anchor

USE (10) 5/8" DIA. SIMPSON TITEN HD (MECH. GALV.)
OR APPROVED EQUAL (EMBED = 4" MIN).

(see attached for anchorage design)

Company:	MSC Engineers Inc	Date:	9/8/2022
Engineer:	JAC	Page:	1/5
Project:	EOU Inlow Hall Generator		
Address:	3470 Pipebend Place NE		
Phone:	503-399-1399		
E-mail:	johnc@mscengineersinc.com		

1. Project information

Customer company:
Customer contact name:
Customer e-mail:
Comment:

Project description:
Location: La Grande, OR
Fastening description: Generator Anchorage

2. Input Data & Anchor Parameters

General

Design method: ACI 318-19
Units: Imperial units

Anchor Information:


Anchor type: Concrete screw
Material: Carbon Steel
Diameter (inch): 0.625
Nominal Embedment depth (inch): 4.000
Effective Embedment depth, h_{ef} (inch): 2.970
Code report: ICC-ES ESR-2713
Anchor category: 1
Anchor ductility: No
 h_{min} (inch): 6.00
 c_{ac} (inch): 4.50
 c_{min} (inch): 1.75
 s_{min} (inch): 3.00

Base Material

Concrete: Normal-weight
Concrete thickness, h (inch): 8.00
State: Cracked
Compressive strength, f'_c (psi): 3000
 $\Psi_{c,v}$: 1.0
Reinforcement condition: Supplementary reinforcement not present
Supplemental edge reinforcement: Not applicable
Reinforcement provided at corners: No
Ignore concrete breakout in tension: No
Ignore concrete breakout in shear: No
Ignore 6do requirement: Not applicable
Build-up grout pad: No

Recommended Anchor

Anchor Name: Titen HD® - 5/8"Ø Titen HD, h_{nom} : 4" (102mm)
Code Report: ICC-ES ESR-2713





Company:	MSC Engineers Inc	Date:	9/8/2022
Engineer:	JAC	Page:	2/5
Project:	EOU Inlow Hall Generator		
Address:	3470 Pipebend Place NE		
Phone:	503-399-1399		
E-mail:	johnc@mscengineersinc.com		

Load and Geometry

Load factor source: ACI 318 Section 5.3

Load combination: not set

Seismic design: Yes

Anchors subjected to sustained tension: Not applicable

Ductility section for tension: 17.10.5.3 (d) is satisfied

Ductility section for shear: 17.10.6.3 (c) is satisfied

Ω_0 factor: not set

Apply entire shear load at front row: No

Anchors only resisting wind and/or seismic loads: No


Strength level loads:

N_{ua} [lb]: 0

V_{uax} [lb]: 0

V_{uay} [lb]: 585

<Figure 1>




1.6



Anchor Designer™
Software
Version 3.1.2209.3

Company:	MSC Engineers Inc	Date:	9/8/2022
Engineer:	JAC	Page:	3/5
Project:	EOU Inlow Hall Generator		
Address:	3470 Pipebend Place NE		
Phone:	503-399-1399		
E-mail:	johnc@mscengineersinc.com		

<Figure 2>



1.7



Company:	MSC Engineers Inc	Date:	9/8/2022
Engineer:	JAC	Page:	4/5
Project:	EOU Inlow Hall Generator		
Address:	3470 Pipebend Place NE		
Phone:	503-399-1399		
E-mail:	johnc@mscengineersinc.com		

3. Resulting Anchor Forces

Anchor	Tension load, N _{ua} (lb)	Shear load x, V _{uax} (lb)	Shear load y, V _{uay} (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	0.0	0.0	585.0	585.0
Sum	0.0	0.0	585.0	585.0

Maximum concrete compression strain (‰): 0.00

Maximum concrete compression stress (psi): 0

Resultant tension force (lb): 0

Resultant compression force (lb): 0

Eccentricity of resultant tension forces in x-axis, e'_{Nx} (inch): 0.00

Eccentricity of resultant tension forces in y-axis, e'_{Ny} (inch): 0.00

Eccentricity of resultant shear forces in x-axis, e'_{Vx} (inch): 0.00

Eccentricity of resultant shear forces in y-axis, e'_{Vy} (inch): 0.00

8. Steel Strength of Anchor in Shear (Sec. 17.7.1)

V _{sa} (lb)	ϕ_{grout}	ϕ	$\phi_{grout}\phi V_{sa}$ (lb)
8000	1.0	0.60	4800

9. Concrete Breakout Strength of Anchor in Shear (Sec. 17.7.2)

Shear perpendicular to edge in y-direction:

$V_{by} = \min[7(l_e/d_a)^{0.2}\sqrt{d_a}\lambda_a\sqrt{f'_c}c_{at}^{1.5}; 9\lambda_a\sqrt{f'_c}c_{at}^{1.5}]$ (Eq. 17.7.2.2.1a & Eq. 17.7.2.2.1b)

l _e (in)	d _a (in)	λ_a	f' _c (psi)	c _{at} (in)	V _{by} (lb)
2.97	0.625	1.00	3000	6.00	6084

$\phi V_{cby} = \phi (A_{vc}/A_{vco}) \Psi_{ed,v} \Psi_{c,v} \Psi_{h,v} V_{by}$ (Sec. 17.5.1.2 & Eq. 17.7.2.1a)

A _{vc} (in ²)	A _{vco} (in ²)	$\Psi_{ed,v}$	$\Psi_{c,v}$	$\Psi_{h,v}$	V _{by} (lb)	ϕ	ϕV_{cby} (lb)
144.00	162.00	1.000	1.000	1.061	6084	0.70	4015

10. Concrete Pryout Strength of Anchor in Shear (Sec. 17.7.3)

$\phi V_{cp} = \phi k_{cp} N_{cb} = \phi k_{cp} (A_{Nc}/A_{Nco}) \Psi_{ed,N} \Psi_{c,N} \Psi_{cp,N} N_b$ (Sec. 17.5.1.2 & Eq. 17.7.3.1a)


k _{cp}	A _{Nc} (in ²)	A _{Nco} (in ²)	$\Psi_{ed,N}$	$\Psi_{c,N}$	$\Psi_{cp,N}$	N _b (lb)	ϕ	ϕV_{cp} (lb)
2.0	79.39	79.39	1.000	1.000	1.000	4766	0.70	6672

11. Results

Interaction of Tensile and Shear Forces (Sec. 17.8)

Shear	Factored Load, V _{ua} (lb)	Design Strength, ϕV_n (lb)	Ratio	Status
-------	-------------------------------------	----------------------------------	-------	--------

Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Anchor Designer™
Software
Version 3.1.2209.3


Company:	MSC Engineers Inc	Date:	9/8/2022
Engineer:	JAC	Page:	5/5
Project:	EOU Inlow Hall Generator		
Address:	3470 Pipebend Place NE		
Phone:	503-399-1399		
E-mail:	johnc@mscengineersinc.com		

Steel	585	4800	0.12	Pass
T Concrete breakout y+	585	4015	0.15	Pass (Governs)
Pryout	585	6672	0.09	Pass

5/8"Ø Titen HD, hnom:4" (102mm) meets the selected design criteria.

12. Warnings

- Per designer input, ductility requirements for tension have been determined to be satisfied – designer to verify.
- Per designer input, ductility requirements for shear have been determined to be satisfied – designer to verify.
- Designer must exercise own judgement to determine if this design is suitable.
- Refer to manufacturer's product literature for hole cleaning and installation instructions.



REV	DATE	BY	DESCRIPTION	SCALE	NOTES
1	05/24/2017	BT	INITIAL DESIGN	1:1	NO NOT SCALE. REFERENCE THE MODEL FOR ALL UNPRECISED DIMENSIONS.
2	06/01/2017	BT	REVISIONS	1:1	
3	06/01/2017	BT	REVISIONS	1:1	
4	06/01/2017	BT	REVISIONS	1:1	
5	06/01/2017	BT	REVISIONS	1:1	
6	06/01/2017	BT	REVISIONS	1:1	
7	06/01/2017	BT	REVISIONS	1:1	
8	06/01/2017	BT	REVISIONS	1:1	
9	06/01/2017	BT	REVISIONS	1:1	
10	06/01/2017	BT	REVISIONS	1:1	
11	06/01/2017	BT	REVISIONS	1:1	
12	06/01/2017	BT	REVISIONS	1:1	
13	06/01/2017	BT	REVISIONS	1:1	
14	06/01/2017	BT	REVISIONS	1:1	
15	06/01/2017	BT	REVISIONS	1:1	
16	06/01/2017	BT	REVISIONS	1:1	
17	06/01/2017	BT	REVISIONS	1:1	
18	06/01/2017	BT	REVISIONS	1:1	
19	06/01/2017	BT	REVISIONS	1:1	
20	06/01/2017	BT	REVISIONS	1:1	
21	06/01/2017	BT	REVISIONS	1:1	
22	06/01/2017	BT	REVISIONS	1:1	
23	06/01/2017	BT	REVISIONS	1:1	
24	06/01/2017	BT	REVISIONS	1:1	
25	06/01/2017	BT	REVISIONS	1:1	
26	06/01/2017	BT	REVISIONS	1:1	
27	06/01/2017	BT	REVISIONS	1:1	
28	06/01/2017	BT	REVISIONS	1:1	
29	06/01/2017	BT	REVISIONS	1:1	
30	06/01/2017	BT	REVISIONS	1:1	
31	06/01/2017	BT	REVISIONS	1:1	
32	06/01/2017	BT	REVISIONS	1:1	
33	06/01/2017	BT	REVISIONS	1:1	
34	06/01/2017	BT	REVISIONS	1:1	
35	06/01/2017	BT	REVISIONS	1:1	
36	06/01/2017	BT	REVISIONS	1:1	
37	06/01/2017	BT	REVISIONS	1:1	
38	06/01/2017	BT	REVISIONS	1:1	
39	06/01/2017	BT	REVISIONS	1:1	
40	06/01/2017	BT	REVISIONS	1:1	
41	06/01/2017	BT	REVISIONS	1:1	
42	06/01/2017	BT	REVISIONS	1:1	
43	06/01/2017	BT	REVISIONS	1:1	
44	06/01/2017	BT	REVISIONS	1:1	
45	06/01/2017	BT	REVISIONS	1:1	
46	06/01/2017	BT	REVISIONS	1:1	
47	06/01/2017	BT	REVISIONS	1:1	
48	06/01/2017	BT	REVISIONS	1:1	
49	06/01/2017	BT	REVISIONS	1:1	
50	06/01/2017	BT	REVISIONS	1:1	
51	06/01/2017	BT	REVISIONS	1:1	
52	06/01/2017	BT	REVISIONS	1:1	
53	06/01/2017	BT	REVISIONS	1:1	
54	06/01/2017	BT	REVISIONS	1:1	
55	06/01/2017	BT	REVISIONS	1:1	
56	06/01/2017	BT	REVISIONS	1:1	
57	06/01/2017	BT	REVISIONS	1:1	
58	06/01/2017	BT	REVISIONS	1:1	
59	06/01/2017	BT	REVISIONS	1:1	
60	06/01/2017	BT	REVISIONS	1:1	
61	06/01/2017	BT	REVISIONS	1:1	
62	06/01/2017	BT	REVISIONS	1:1	
63	06/01/2017	BT	REVISIONS	1:1	
64	06/01/2017	BT	REVISIONS	1:1	
65	06/01/2017	BT	REVISIONS	1:1	
66	06/01/2017	BT	REVISIONS	1:1	
67	06/01/2017	BT	REVISIONS	1:1	
68	06/01/2017	BT	REVISIONS	1:1	
69	06/01/2017	BT	REVISIONS	1:1	
70	06/01/2017	BT	REVISIONS	1:1	
71	06/01/2017	BT	REVISIONS	1:1	
72	06/01/2017	BT	REVISIONS	1:1	
73	06/01/2017	BT	REVISIONS	1:1	
74	06/01/2017	BT	REVISIONS	1:1	
75	06/01/2017	BT	REVISIONS	1:1	
76	06/01/2017	BT	REVISIONS	1:1	
77	06/01/2017	BT	REVISIONS	1:1	
78	06/01/2017	BT	REVISIONS	1:1	
79	06/01/2017	BT	REVISIONS	1:1	
80	06/01/2017	BT	REVISIONS	1:1	
81	06/01/2017	BT	REVISIONS	1:1	
82	06/01/2017	BT	REVISIONS	1:1	
83	06/01/2017	BT	REVISIONS	1:1	
84	06/01/2017	BT	REVISIONS	1:1	
85	06/01/2017	BT	REVISIONS	1:1	
86	06/01/2017	BT	REVISIONS	1:1	
87	06/01/2017	BT	REVISIONS	1:1	
88	06/01/2017	BT	REVISIONS	1:1	
89	06/01/2017	BT	REVISIONS	1:1	
90	06/01/2017	BT	REVISIONS	1:1	
91	06/01/2017	BT	REVISIONS	1:1	
92	06/01/2017	BT	REVISIONS	1:1	
93	06/01/2017	BT	REVISIONS	1:1	
94	06/01/2017	BT	REVISIONS	1:1	
95	06/01/2017	BT	REVISIONS	1:1	
96	06/01/2017	BT	REVISIONS	1:1	
97	06/01/2017	BT	REVISIONS	1:1	
98	06/01/2017	BT	REVISIONS	1:1	
99	06/01/2017	BT	REVISIONS	1:1	
100	06/01/2017	BT	REVISIONS	1:1	

