

INVITATION TO BIDDERS #2024-03
ROOF REPLACEMENT PROJECT – SNELL HALL AND ATHLETICS BUILDING
RESPONSE TO CLARIFYING QUESTIONS TWO
May 3, 2024

Note that these are questions submitted by interested firms to this solicitation. The below answers are for clarification purposes only and in no way alter or amend the BID as published.

1. QUESTION: Were there core cuts taken on both buildings, and the locations on the Snell Hall and the Athletics Building? This information is needed to determine the type/types of roofing, thickness of the existing to compare against the new elevations for the new tapered insulation and Alternate Poly Iso add of 2 layers of 2.6” insulation.

ANSWER:

- Snell Hall Roof Core – Material was wet and crumbly difficult to get full depth continuous core. Thickness to pan deck approx. 6 inches.



- Athletics Roof Core – Material dry and thickness to pan deck approx. 3 inches.



End of Clarifying Questions