



REQUEST FOR PROPOSALS #FP-2024-04A & -05A
EOU LIBRARY & ACKERMAN HVAC RENEWALS
Response to Contractor Questions

Note that these are questions submitted by interested firms to this solicitation. The answers below are for clarification purposes only and in no way alter or amend the RFP as published.

1. **Question:** Library Scope Add Alternate #1 – Furnish and Install IP Chilled beam controllers to match the units being installed in Inlow Hall. By match, is it expected to be the same manufacture or same functionality? If manufacture, can you clarify who the manufacturer is?

Answer: Same manufacture and functionality – specifically Distech with a BACnet over IP Communication protocol.

2. **Question:** Ackerman Hall Add Alternate #1 – Replace JCI Controller on AHU#3 with New Controller. Specifically, it states replace with New Distech Controller. Is Distech the Only approved manufacture for the controls in Ackerman Hall?

Answer: Yes, Distech is EOU's non-proprietary standard manufacturer across campus.

END OF EOU RESPONSES TO QUESTIONS