

REQUEST FOR QUOTES #2025-04
OMIC R&D – EQUIPMENT INSTALLATION ELECTRICAL SERVICES
RESPONSE TO CLARIFYING QUESTIONS TWO
May 20, 2025

Note that these are questions submitted by interested firms to this solicitation. The below answers are for clarification purposes only and in no way alter or amend the solicitation as published.

1. **QUESTION:** Is the SO cord from the machines to the outlets provided by the manufacturer? Or is that on the Contractor to provide?
ANSWER: OMIC expects the Contractor to size and provide the SO cable.

End of Clarifying Questions