

INVITATION TO BID #2025-01
OMIC R&D – HM1000 FOUNDATION AND MACHINE INSTALLATION
RESPONSE TO CLARIFYING QUESTIONS TWO
May 23, 2025

Note that these are questions submitted by interested firms to this solicitation. The below answers are for clarification purposes only and in no way alter or amend the solicitation as published.

1. **QUESTION:** With reference to General Structural Drawing, are any Special Inspections (i.e. subgrade compaction, rebar, concrete sampling) required?
ANSWER: Yes, the engineering team recommends special inspections on the subgrade compaction and verification of rebar install. The rebar verification could be through the building permit inspection prior to pouring the concrete. Concrete mix design should be submitted, but concrete samples / testing are not necessary.

End of Clarifying Questions