

7th Street

8th Street 15 418

G Avenue

Quinn Coliseum


Piezometer B-1

Apprx.
Sump Pit

Piezometer B-2



BORING LOG - NV5 - 1 PER PAGE EOU-4-02-B1_2.GPJ GDI_NV5.GDT PRINT DATE: 8/25/22:KT



DRILLED BY: Western States Soil Conservation, Inc.

LOGGED BY: H. Herinckx

COMPLETED: 07/18/22

BORING METHOD: mud rotary (see document text)

BORING BIT DIAMETER: 4 7/8 inches



EOU-4-02


BORING B-1

SEPTEMBER 2022

EOU STEAM TUNNEL SYSTEM IMPROVEMENTS
LA GRANDE, OR

FIGURE A-1

BORING LOG - NV5 - 1 PER PAGE EOU-4-02-B1_2.GPJ GDI_NV5.GDT PRINT DATE: 8/25/22:KT



DRILLED BY: Western States Soil Conservation, Inc.

LOGGED BY: H. Herinckx

COMPLETED: 07/18/22

BORING METHOD: mud rotary (see document text)

BORING BIT DIAMETER: 4 7/8 inches




EOU-4-02

BORING B-2

SEPTEMBER 2022

EOU STEAM TUNNEL SYSTEM IMPROVEMENTS
LA GRANDE, OR

FIGURE A-2



BOULDERS	COBBLES	GRAVEL		SAND			FINES	
		COARSE	FINE	COARSE	MEDIUM	FINE	SILT	CLAY

KEY	EXPLORATION NUMBER	SAMPLE DEPTH (FEET)	MOISTURE CONTENT (PERCENT)	D60	D50	D30	D10	D5	GRAVEL (PERCENT)	SAND (PERCENT)	SILT (PERCENT)	CLAY (PERCENT)
●	B-1	7.5	18	4.72	2.71	0.71			40	48		12



EOU-4-02

GRAIN-SIZE TEST RESULTS

AUGUST 2022

EOU STEAM TUNNEL SYSTEM IMPROVEMENTS
LA GRANDE, OR

FIGURE

SAMPLE INFORMATION			MOISTURE CONTENT (PERCENT)	DRY DENSITY (PCF)	SIEVE			ATTERBERG LIMITS		
EXPLORATION NUMBER	SAMPLE DEPTH (FEET)	ELEVATION (FEET)			GRAVEL (PERCENT)	SAND (PERCENT)	P200 (PERCENT)	LIQUID LIMIT	PLASTIC LIMIT	PLASTICITY INDEX
B-1	7.5		18		40	48	12			
B-1	20.0		20				11			
B-2	10.0		20				15			
B-2	20.0		18				9			

LAB SUMMARY - GDI-NV5 EOU-4-02-B1_2.GPJ GDI_NV5.GDT PRINT DATE: 8/25/22.

	EOU-4-02	SUMMARY OF LABORATORY DATA		
	AUGUST 2022	EOU STEAM TUNNEL SYSTEM IMPROVEMENTS LA GRANDE, OR	FIGURE	